

N : DoP LUX TEP-TEV_indC

DECLARATION OF PERFORMANCE OF SMOKE AND HEAT CONTROL SYSTEMS

9. Declared performances :

Harmonised technical specification: EN 12101-2:2003	Essential characteristics	Performance
	Nominal activation conditions / sensitivity, as: Initiation device Opening mechanism Inputs and outputs	present present present
	Response delay (response time), as: Reliability Opening under (snow, wind) load Low ambient temperature Fire Performance	≤ 60 s
	Operational reliability, as: Reliability	Re 1000, Type B Re 1000 (+10 000), Type B
	Effectiveness of smoke/hot gas extraction, as: Aerodynamic free area	with upstand without upstand
	Performance parameters under fire conditions, as: Resistance to heat Mechanical stability Reaction to fire	$A_{s0} = A_v * C_v^{**}$ $A_{s1} = A_v * C_v^{**}$ B ₃₀₀ 30 $\Delta A_{trémie} < 10 \%$
	Performance under environmental conditions, as: Opening under load (see tables) Low ambient temperature Stability under wind load Resistance to wind-induced vibration (where included) Resistance to heat	Glass blades Polycarbonate blades
	Durability, as: Response delay (response time) Operational reliability	≤ 60 s Re 1000 Re 1000 (+10 000)
	Performance parameters under fire conditions	≤ 60 s; $\Delta A_{trémie} < 10 \%$

*****Determination of the snowload classification :**

CERTILUX TEP :

Type of motor	Performance	Av
1 motor 0,8A or 1A	SL 250	0,2 to 2,55 m ²
	SI 0	2,55 to 6 m ²
2 motor (2 x 0,8 A)	SL 250	2,55 to 5,1 m ²
	SI 0	5,1 to 7 m ²

CERTILUX TEV :

Type of motor	Performance	Av
1 motor 0,8A or 1A	SL 250	0,2 to 1,6 m ²
	SL 0	1,6 to 2 m ²
1 motor (2 x 0,8 A)	SL 250	1,6 to 3,2 m ²
	SL 0	3,2 to 7m ²

****Definition of flow coefficient**

		With upstand 280 mm		With upstand 350 mm		Without upstand	
		500 ≤ L < 1000	1000 ≤ L ≤ 2000	500 ≤ L < 1000	1000 ≤ L ≤ 2000	500 ≤ L < 1000	1000 ≤ L ≤ 2000
With Av ≤ 6m² Windshields=265 mm	H < 1000	0,55	0,55			0,50	0,50
	H ≥ 1000	0,55	0,67			0,50	0,62
With Av > 6m² Windshields=310 mm	H ≤ 3513				0,64		0,62

10. *The performance of the product identified in points 1 et 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.*

Signed for and on behalf of the manufacturer by: **David Maillart – R&D Manager**

The 18/04/2023
In Collégien

