

N : DoP POLYBAIE OFBCE _ind B

DECLARATION OF PERFORMANCE OF SMOKE AND HEAT CONTROL SYSTEMS

1. *Unique identification code of the product-type:* **Polybaie OFBCE**
2. *Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11 paragraph 4:*
Information given on the tracking label :
Order confirmation Number + Product Number + Date of production
3. *Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer :*

3.1 Product description : Natural smoke and heat exhaust ventilator with a single casement, for wall installation on a horizontal axis in a bottom or top hung opening outside configuration, or on a vertical axis side hung opening outside style. The infill can be in cellular polycarbonate, in glass or insulated double skin aluminium (thermally or acoustically).

3.2 Installation and implementation conditions in accordance with the certified performances

- Wall installation ($\pm 30^\circ$)
- Dimensional range (Throat dimensions)

	Bottom or top hunged		Side hunged			
			When : If Lpa \geq 2 x Hpa If Lpa \geq 3 x Hpa			
	Minimum	Maximum	Minimum	Maximum		
LPA (mm)	550	2400	1600	600	2400	1800
HPA (mm)	300	1200	1600	300	800	900

3.3 Mode of operation: Electrical opening and closing
Voltage $U_a = U_c = 24$ Vcc or 230 Vac
Power $P_a = P_c$ absorbed in a steady state
17 to 90 W max according to the actuator

3.4 Possible options :
Open / Close position switches
Thermal device release (according to the current standard).

4. *Name, registered trade name or trademark, in conformity with article 11, paragraph 5:*

Company name SOUCHIER – BOULLET SAS
Parc Segro – 42 rue de Lamirault
CS 20762
77090 COLLEGIEN
France

Production unit : SOUCHIER-BOULLET SAS
11 rue du 47^{ème} R.A.
70400 HERICOURT
France

6. *7. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:*

The notified body TÜV Rheinland N° 0336 performed the determination of the product type on the basis of type testing, type calculation of the product, the initial inspection of the manufacturing plant and the factory production control and the continuous surveillance, assessment and evaluation of the factory production control under system 1 and issued the certificate of constancy of performance N°

CE Certificate N°0336 – CPR – 89208433.

9. *Declared performances :*

	Essential characteristics	Performance
Harmonised technical specification: EN 12101-2:2003	Nominal activation conditions / sensitivity, as: Initiation device Opening mechanism Inputs and outputs	present present present
	Response delay (response time), as: Reliability Opening under (snow, wind) load Low ambient temperature Fire Performance	≤ 60 s
	Operational reliability, as: Reliability	Re 1000 (+10 000), Type B
	Effectiveness of smoke/hot gas extraction, as: Aerodynamic free area (See page 3)	$A_v = A_v^* \times C_v^{**}$
	Performance parameters under fire conditions, as: Resistance to heat Mechanical stability Reaction to fire Panel or glass insulated Polycarbonate	$B_{300} 30$ $\Delta A_{throat} < 10 \%$ A1 B-s1;d0
	Performance under environmental conditions, as: Opening under load Low ambient temperature Stability under wind load Resistance to wind-induced vibration (where included) Resistance to heat	SL NPD T(00) WL 1500 NPD $B_{300} 30$
	Durability, as: Response delay (response time) Operational reliability Performance parameters under fire conditions	≤ 60 s Re 1000 (+10 000) ≤ 60 s; $\Delta A_{throat} < 10 \%$


Calculation of the free aerodynamic surface

$$A_a = A_v \times C_v^{**}$$

$$A_v = L_{pa} \times H_{pa}$$

DECLARATION OF PERFORMANCE OF SMOKE AND HEAT CONTROL SYSTEMS

**** Cv : Calculation of flow coefficient :**



10. The performance of the product identified in points 1 et 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by: **David Maillart – R&D Manager**

The 28/03/2024
In Collégien

