



Notified Body nr. 0336

Certificate of constancy of performance

0336 – CPR – 89223990-H

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

Natural smoke and heat exhaust ventilator with intended use to be installed as a component of natural smoke and heat exhaust system

Specified by the commercial name(s)
CERTILIGHT VISION

placed on the market under the name or trade mark
SOUCHIER-BOULLET S.A.S,
PARC SEGRO - ZAC DE LAMIRAULT, 42 RUE DE LAMIRAULT, CS 20762, 77090
COLLEGIEN - France

and produced in the manufacturing plant(s)
SOUCHIER-BOULLET S.A.S,
11 rue du 47ème Régiment d'Artillerie, 70400 HERICOURT, France

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of standard(s)

EN 12101-2:2003

under system 1 for the performances set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product

This certificate was first issued on 4th April 2024 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the notified product certification body.

TÜV Rheinland Nederland BV
Westervoortsedijk 73
NL – 6827 AV Arnhem
The Netherlands

Arnhem, 4th April 2024

T.W.J. Zandvliet, Local Field Manager

Certificate of constancy of performance

0336 – CPR – 89223990-H

Annex 1 Natural smoke and heat exhaust ventilator

Commercial name :
CERTILIGHT VISION

Certified range	Dimensions: $800 \text{ mm} \leq A \leq 3000 \text{ mm}$ $700 \text{ mm} \leq B \leq 1600 \text{ mm}$ A = Overall width parallel to the hinges B = Overall height perpendicular to the hinges Geometric area: $0,70 \text{ m}^2 \leq A_v \leq 6,71 \text{ m}^2$ Variants/type: Without upstand With or without wind deflector With or without fall through protections (grids) With or without protective casing		
Characteristic	Declared values	Reference	Laboratory or Not. Body
Aerodynamic free area Aa (Annex B)	Aa depending of the type	Test report no. C2A-23-21326	0679
Reliability (Annex C)	Re 1.000 and Re 1.000 (+10.000) Dual purpose allowed	Test report no. EFR-22-001391	1812
Opening under load (Annex D)	SL 0 up to SL 1000	Test report no. C2A-23-14352/D	0679
Low ambient temperature (Annex E)	T(00)	not tested default value	N/A
Wind load (Annex F)	WL 1500	Test report no. C2A-22-14371-F1; EFR-22-001391	0679; 1812
Resistance to heat (Annex G)	B 300	Test report no. EFR-21-H-002131	1812
Reaction to fire of the infill (Annex G)	"B-s1, d0 (fillings PCA) A 1 (glass filling and metal filling with single or double walled insulated or non insulated)"	N/A	N/A

Related Notified Bodies :
 0679 : Centre Scientifique et Technique du Bâtiment (CSTB)
 1812 : EFECTIS France

- End of Certificate -

4th April 2024
Page 2 of 2