

## DECLARATION OF PERFORMANCE OF SMOKE AND HEAT CONTROL SYSTEMS

1. *Unique identification code of the product-type:*

**CERTILUX TE(spR)P**

2. *Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11 paragraph 4:*  
**Information given on the tracking label :**

**Order confirmation Number + Product Number + Date of production**

3. *Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer ::*

### 3.1 Product description :

Natural smoke and heat exhaust ventilator (NSHEV) for roof installation with polycarbonate blades.

### 3.2 Installation and implementation conditions in accordance with the certified performances

- Roof installation from 5° to 60°
- Dimensional range : **L** and **H** are the throat dimensions of the product  
 $L = \text{width in m and } H = \text{height in m}$   
 $0,873 \leq H \leq 1,368 \text{ and } 0,731 \leq L \leq 1,2$ 

With  $1\text{m}^2 \leq A_v^* \leq 1,64\text{m}^2$   
 $* : A_v = L \times H$
- With mandatory fixed windshields, to ensure  $C_v$  coefficient declared in page 2
- Without or with 280 mm high steel upstand, with or without insulation, to ensure  $C_v$  coefficient declared in page 2

### 3.3 Mode of operation :

Fail safe opening and closing with power

Voltage  $U_a = U_c = 24 \text{ Vcc}$  – Wattage  $P_a = P_c$  absorbed in a steady state

- 1,5 W maxi in waiting state
- 5 W maxi for closing

### 3.4 Possible options :

Open / Close position switches.

Thermal device release (according to the current standard).

4. *Name, registered trade name or trade mark , in conformity with article 11, paragraph 5:*

**Company name** SOUCHIER – BOULLET SAS

Parc Segro – 42 rue de Lamirault

CS 20762

77090 COLLEGIEN

France

**Production unit :** SOUCHIER-BOULLET SAS

11 rue du 47<sup>ème</sup> R.A.

70400 HERICOURT

France

6. 7. *System or systems of assessment and verification of constancy of performance of the construction product in accordance to Annex V.*

The notified body **TÜV Rheinland N° 0336** performed the determination of the product type on the basis of type testing, type calculation of the product, the initial inspection of the manufacturing plant and the factory production control and the continuous surveillance, assessment and evaluation of the factory production control under system 1 and issued the certificate of constancy of performance N°

**CE Certificate N°0336 – CPR – 6742-1-1**

## DECLARATION OF PERFORMANCE OF SMOKE AND HEAT CONTROL SYSTEMS

### 9. Declared performances :

Harmonised technical specification: EN 12101-2:2003	Essential characteristics	Performance
	Nominal activation conditions / sensitivity, as:	
	Initiation device	present
	Opening mechanism	present
	Inputs and outputs	present
	Response delay (response time), as:	
	Reliability	
	Opening under (snow, wind) load	≤ 60 s
	Low ambient temperature	
	Fire Performance	
	Operational reliability, as:	
	Reliability	Re 1000, Type B
	Effectiveness of smoke/hot gas extraction, as:	
	Aerodynamic free area	with upstand $A_a = A_v * C_v^{**}$ without upstand $A_a = A_v * C_v^{**}$
	Performance parameters under fire conditions, as:	
	Resistance to heat	$B_{300} 30$
	Mechanical stability	$\Delta A_{trémie} < 10 \%$
	Reaction to fire	
	Polycarbonate blades	B-s1;d0
	Performance under environmental conditions, as:	
	Opening under load (see tables)	SL ** *
	Low ambient temperature	T(00)
	Stability under wind load	WL 1500
	Resistance to wind-induced vibration (where included)	$\omega_0: > 10\text{Hz}$ , $\delta: > 0,1$
	Resistance to heat	$B_{300} 30$
	Durability, as:	
	Response delay (response time)	≤ 60 s
	Operational reliability	Re 1000
	Performance parameters under fire conditions	≤ 60 s; $\Delta A_{trémie} < 10 \%$

### \*\*\*Determination of the snowload classification :

#### CERTILUX TE(spR)P :

Performance	Av
SL 250	1 to 1,64 m <sup>2</sup>

### \*\*Definition of flow coefficient

		With upstand 280 mm		Without upstand	
		L < 1000	L ≥ 1000	L < 1000	L ≥ 1000
Windshields = 265 mm	H < 1000	0,55	0,55	0,50	0,50
	H ≥ 1000	0,55	0,67	0,50	0,62

10. The performance of the product identified in points 1 et 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4

Signed for and on behalf of the manufacturer by: **David Maillart – R&D Manager**

The 18/04/2023

In Collégien

