



Notified Body nr. 0336

## Certificate of constancy of performance

0336 – CPR – 89223981-H

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

### **Natural smoke and heat exhaust ventilator with intended use to be installed as a component of natural smoke and heat exhaust system**

Specified by the commercial name(s)  
**VENTILIGHT VISION**

placed on the market under the name or trade mark  
**SOUCHIER-BOULLET S.A.S,**  
**PARC SEGRO - ZAC DE LAMIRAULT, 42 RUE DE LAMIRAULT, CS 20762,**  
**77090 COLLEGIEN - France**

and produced in the manufacturing plant(s)  
**SOUCHIER-BOULLET S.A.S,**  
**11 rue du 47ème Régiment d'Artillerie, 70400 HERICOURT, France**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of standard(s)

#### **EN 12101-2:2003**

under system 1 for the performances set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product

This certificate was first issued on 8<sup>th</sup> May 2024 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the notified product certification body.

TÜV Rheinland Nederland BV  
Westervoortsedijk 73  
NL – 6827 AV Arnhem  
The Netherlands

Arnhem, 8<sup>th</sup> May 2024

T.W.J. Zandvliet, Local Field Manager

# Certificate of constancy of performance

## 0336 – CPR – 89223981 – H

### Annex 1 Natural smoke and heat exhaust ventilator

Commercial name :  
**VENTILIGHT VISION**

<b>Certified range</b>	Dimensions: 800 mm ≤ A ≤ 3000 mm 700 mm ≤ B ≤ 1600 mm A = Overall width parallel to the hinges B = Overall height perpendicular to the hinges Geometric area: 0,29 m <sup>2</sup> ≤ Av ≤ 3,12 m <sup>2</sup>  Variants/type: Without upstand With or without wind deflector With or without fall through protections (grids) With or without protective casing In single line mounting On sloping roof		
<b>Characteristic</b>	<b>Declared values</b>	<b>Reference</b>	<b>Laboratory or Not. Body</b>
<b>Aerodynamic free area Aa (Annex B)</b>	Aa depending of the type	Test report no. C2A-23-15775 C2A-22-09823 C2A-22-09862	0679
<b>Reliability (Annex C)</b>	Re 1.000 and Re 1.000 (+10.000) Dual purpose allowed	Test report no. EFR-22-001391	1812
<b>Opening under load (Annex D)</b>	SL 0 up to SL 1000	Test report no. C2A-23-14352/D	0679
<b>Low ambient temperature (Annex E)</b>	T(00)	not tested default value	N/A
<b>Wind load (Annex F)</b>	WL 1500	Test report no. C2A-22-14371-F2; EFR-22-001391	0679; 1812
<b>Resistance to heat (Annex G)</b>	B 300	Test report no. EFR-21-H-002131	1812
<b>Reaction to fire of the infill (Annex G)</b>	"B-s1, d0 (fillings PCA) A 1 (glass filling and metal filling with single or double walled insulated or non insulated)"	N/A	N/A

Related Notified Bodies :  
 0679 : Centre Scientifique et Technique du Bâtiment (CSTB)  
 1812 : EFECTIS France

- End of Certificate -

8<sup>th</sup> May 2024  
Page 2 of 2