

DECLARATION OF PERFORMANCE OF SMOKE AND HEAT CONTROL SYSTEMS

1. Unique identification code of the product-type:

CERTILAM TP(MRR)S
CERTILAM TP(MRR)I

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11 paragraph 4:
Information given on the tracking label :

Order confirmation Number + Product Number + Date of production

3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer :

3.1 Product description :

Natural smoke and heat exhaust ventilator (NSHEV) for roof installation with aluminium blades which can be thermally or acoustically insulated.

3.2 Installation and implementation conditions in accordance with the certified performances

- Roof installation from 0° to 60°

- Dimensional range : L and H are the throat dimensions of the product

L = width in m and H = height in m

0,796 ≤ H ≤ 3,546 and 0,5 ≤ L ≤ 2,400 with standard blades

0,781 ≤ H ≤ 3,554 and 0,5 ≤ L ≤ 2,400 with insulated blades

With $1\text{m}^2 \leq A_v^* \leq 7\text{m}^2$

* : $A_v = L \times H$

- With mandatory fixed windshields, to ensure Cv coefficient declared in page 2.
- Without or with 280 or 350 mm high steel upstand, with or without insulation, to ensure Cv coefficient declared in page 2.

3.3 Mode of operation :

Pneumatic opening and closing

Service pressure : 10 to 20 bars (cylinder volume: 4,1 NI under 10 bars)

(Possibility to use the NSHEV for daily ventilation under 6 to 8,5 bars pressure)

3.4 Possible options :

Open / Close position switches

Thermal device release (according to the current standard).

4. Name, registered trade name or trade mark , in conformity with article 11, paragraph 5:

Company name : SOUCHIER – BOULLET SAS

Parc Segro – 42 rue de Lamirault

CS 20762

77090 COLLEGIEN

France

Production unit : SOUCHIER-BOULLET SAS

11 rue du 47^{ème} R.A.

70400 HERICOURT

France

6. 7. System or systems of assessment and verification of constancy of performance of the construction product in accordance to Annex V:

The notified body **TÜV Rheinland N° 0336** performed the determination of the product type on the basis of type testing, type calculation of the product, the initial inspection of the manufacturing plant and the factory production control and the continuous surveillance, assessment and evaluation of the factory production control under system 1 and issued the certificate of constancy of performance N°.

CE Certificate N°0336 – CPR – 6742-1-1

DECLARATION OF PERFORMANCE OF SMOKE AND HEAT CONTROL SYSTEMS

9. Declared performances :

Harmonised technical specification: EN 12101-2:2003	Essential characteristics	Performance
	Nominal activation conditions / sensitivity, as: Initiation device Opening mechanism Inputs and outputs	present present present
	Response delay (response time), as: Reliability Opening under (snow, wind) load Low ambient temperature Fire Performance	≤ 60 s
	Operational reliability, as: Reliability	Re 1000, Type B
	Effectiveness of smoke/hot gas extraction, as: Aerodynamic free area	with upstand without upstand $A_a = A_v^* \times C_v^{**}$ $A_a = A_v^* \times C_v^{**}$
	Performance parameters under fire conditions, as: Resistance to heat Mechanical stability Reaction to fire	$B_{300} 30$ $\Delta A_{trémie} < 10 \%$ Standard blades Insulated blades A1 B-s1;d0
	Performance under environmental conditions, as: Opening under load (see tables) Low ambient temperature Stability under wind load Resistance to wind-induced vibration (where included) Resistance to heat	SL ** * T(00) WL 1500 $\omega_0: > 10\text{Hz}$, $\delta: > 0,1$ $B_{300} 30$
	Durability, as: Response delay (response time) Operational reliability Performance parameters under fire conditions	≤ 60 s Re 1000 ≤ 60 s; $\Delta A_{trémie} < 10 \%$

***Determination of the snowload classification : (under 10 bars)

CERTILAM TP(MRR)S :

Performance	Av
SL 500	1 to 4,31 m ²
SL 250	4,31 to 6 m ²
SL 250	6 to 7 m ² if L ≤ 2000 mm
SL 0	6 to 7 m ² if L > 2000 mm

CERTILAM TP(MRR)I :

Performance	Av
SL 500	1 to 3,74 m ²
SL 250	3,74 to 5,91 m ²
SL 0	5,91 to 7 m ²

** Definition of flow coefficient

		With upstand 280 mm		With upstand 350 mm		Without upstand	
		500 ≤ L < 1000	1000 ≤ L ≤ 2400	500 ≤ L < 1000	1000 ≤ L ≤ 2400	500 ≤ L < 1000	1000 ≤ L ≤ 2400
With Av ≤ 6m ² windshields=265 mm	H < 1000	0,55	0,55			0,50	0,50
	H ≥ 1000	0,55	0,67			0,50	0,62
With Av > 6m ² windshield =310 mm	H ≤ 3554				0,64		0,62

10. The performance of the product identified in points 1 et 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by: **David Maillart – R&D Manager**

The 18/04/2023
In Collégien

