

## DECLARATION OF PERFORMANCE OF SMOKE AND HEAT CONTROL SYSTEMS

1. *Unique identification code of the product-type:*

**CERTILUX TMP  
CERTILUX TMV**

2. *Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11 paragraph 4:*  
**Information given on the tracking label :**

***Order confirmation Number + Product Number + Date of production***

3. *Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer :*

**3.1 Product description :** Natural smoke and heat exhaust ventilator (NSHEV) for roof installation with polycarbonate or glass blades.

**3.2 Installation and implementation conditions in accordance with the certified performances**

- Roof installation from 0° to 60° with glass blades
- Roof installation from 5° to 60° with polycarbonate blades
- Dimensional range : **L** and **H** are the throat dimensions of the product  
**L** = width in m and **H** = height in m  
 $0,873 \leq H \leq 3,018$  and  $0,5 \leq L \leq 2$       With  $1m^2 \leq A_v^* \leq 2,2m^2$  with polycarbonate blades  
and  $1m^2 \leq A_v^* \leq 2m^2$  with glass blades  
**\* :  $A_v = L \times H$**

- With mandatory fixed windshields, to ensure Cv coefficient declared in page 2
- Without or with 280 mm high steel upstand, with or without insulation, to ensure Cv coefficient declared in page 2

**3.3 Mode of operation :** Opening by intrinsic energy and rearming by steel cable traction

**3.4 Possible options :**

Open / Close position switches

Thermal device release (according to the current standard).

4. *Name, registered trade name or trade mark , in conformity with article 11, paragraph 5:*

**Company name :** SOUCHIER – BOULLET SAS  
Parc Segro – 42 rue de Lamirault  
CS 20762  
77090 COLLEGIEN  
France

**Production unit :** SOUCHIER-BOULLET SAS  
11 rue du 47<sup>ème</sup> R.A.  
70400 HERICOURT  
France

6. 7. *System or systems of assessment and verification of constancy of performance of the construction product in accordance to Annex V.*

The notified body **TÜV Rheinland N° 0336** performed the determination of the product type on the basis of type testing, type calculation of the product, the initial inspection of the manufacturing plant and the factory production control and the continuous surveillance, assessment and evaluation of the factory production control under system 1 and issued the certificate of constancy of performance N°

**CE Certificate N°0336 – CPR – 6742-1-1**

## DECLARATION OF PERFORMANCE OF SMOKE AND HEAT CONTROL SYSTEMS

### 9. Declared performances :

| Harmonised technical specification: EN 12101-2:2003 | Essential characteristics                             | Performance  |
|---|---|--|
|   | Nominal activation conditions / sensitivity, as:      |  |
|   | Initiation device                                     | present  |
|   | Opening mechanism                                     | present  |
|   | Inputs and outputs                                    | present  |
|   | Response delay (response time), as:                   |  |
|   | Reliability   |  |
|   | Opening under (snow, wind) load                       | ≤ 60 s   |
|   | Low ambient temperature                               |  |
|   | Fire Performance                                      |  |
|   | Operational reliability, as:                          |  |
|   | Reliability   | Re 300 (+10 000), Type B                                       |
|   | Effectiveness of smoke/hot gas extraction, as:        |  |
|   | Aerodynamic free area                                 | with upstand<br>without upstand                                |
|   |   | $A_0 = A_v^* \times C_v^{**}$<br>$A_0 = A_v^* \times C_v^{**}$ |
|   | Performance parameters under fire conditions, as:     |  |
|   | Resistance to heat                                    | B <sub>300</sub> 30  |
|   | Mechanical stability                                  | $\Delta A_{trémie} < 10 \%$                                    |
|   | Reaction to fire                                      |  |
|   |   | Glass blades A1<br>Polycarbonate blades B-s1;d0                |
|   | Performance under environmental conditions, as:       |  |
|   | Opening under load (see tables)                       | SL ** *  |
|   | Low ambient temperature                               | T(-25)   |
|   | Stability under wind load                             | WL 1500  |
|   | Resistance to wind-induced vibration (where included) | $\omega_0 > 10\text{Hz}$ , $\delta > 0,1$                      |
|   | Resistance to heat                                    | B <sub>300</sub> 30  |
|   | Durability, as:                                       |  |
|   | Response delay (response time)                        | ≤ 60 s   |
|   | Operational reliability                               | Re 300 (+10 000)   |
|   | Performance parameters under fire conditions          | ≤ 60 s; $\Delta A_{trémie} < 10 \%$                            |

### \*\*\*Determination of the snowload classification :

#### CERTILUX TMP :

| Performance | A <sub>v</sub>          |
|-------------|-------------------------|
| SL 500      | 1 to 2,2 m <sup>2</sup> |

#### CERTILUX TMV :

| Performance | A <sub>v</sub>           |
|-------------|--------------------------|
| SL 500      | 1 to 1,85 m <sup>2</sup> |
| SL 250      | 1,85 to 2 m <sup>2</sup> |

### \*\* Definition of flow coefficient

|                      |          | With upstand 280 mm |                 | Without upstand |                 |
|----------------------|----------|---------------------|-----------------|-----------------|-----------------|
|                      |          | 500 ≤ L < 1000      | 1000 ≤ L ≤ 2000 | 500 ≤ L < 1000  | 1000 ≤ L ≤ 2000 |
| Windshields = 265 mm | H < 1000 | 0,55                | 0,55            | 0,50            | 0,50            |
|                      | H ≥ 1000 | 0,55                | 0,67            | 0,50            | 0,62            |

10. The performance of the product identified in points 1 et 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by: **David Maillart – R&D Manager**

The 18/04/2023  
In Collégien

