DECLARATION OF PERFORMANCE OF SMOKE AND HEAT CONTROL SYSTEMS

1.   *Unique identification code of the product-type:*   **Polybaie OFPI**

2.   *Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11 paragraph 4:*
Information given on the tracking label :

Order confirmation Number + Product Number + Date of production

3.   *Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer :*

3.1 *Product description :* Natural smoke and heat exhaust ventilator with a single casement, for wall installation on a horizontal axis in a bottom or top hung opening inside configuration, or on a vertical axis side hung opening inside style. The infill can be in cellular polycarbonate, in glass or insulated double skin aluminium (thermally or acoustically).

3.2 *Installation and implementation conditions in accordance with the certified performances*
- Wall installation (±30°)
- Dimensional range :
(Throat dimensions)

	Bottom or top hunged			Side hunged			
				With :	If Lpa ≥ 2 x Hpa IF Lpa ≥ 3 x Hpa		
	Minimum	Maximum		Minimum	Maximum		
LPA (mm)	300	2400	1600	600	2400	1800	
HPA (mm)	300	1200	1600	300	800	900	

3.3 *Mode of operation :* Pneumatical opening only
Service pressure 6 to 20 bars
(Micro-cylinder volume:0.12Nl under 10 bars)

3.4 *Options possibles :*
Open / Close position switches
Thermal device release (according to the current standard).

4.   *Name, registered trade name or trade mark , in conformity with article 11, paragraph 5:*

Company name : SOUCHIER – BOULLET SAS
Parc Segro – 42 rue de Lamirault
CS 20762
77090 COLLEGIEN
France

Production unit : SOUCHIER-BOULLET SAS
11 rue du 47ème R.A.
70400 HERICOURT
France

6.   7.   *System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:*

The notified body **TÜV Rheinland N° 0336** performed the determination of the product type on the basis of type testing, type calculation of the product, the initial inspection of the manufacturing plant and the factory production control and the continuous surveillance, assessment and evaluation of the factory production control under system 1 and issued the certificate of constancy of performance N°

CE Certificate N°0336 – CPR – 89208433.

9.   *Declared perfomances:*

| Essential characteristics	Performance
Nominal activation conditions / sensitivity, as:	
Initiation device	present
Opening mechanism	present
Inputs and outputs	present
Response delay (response time), as:	
Reliability	
Opening under (snow, wind) load	≤ 60 s
Low ambient temperature	
Fire Performance	
Operational reliability, as:	
Reliability	Re 1000, Type A
Effectiveness of smoke/hot gas extraction, as:	
Aerodynamic free area (see diagrams)	$A_a = A_v* \times C_v**$
Performance parameters under fire conditions, as:	
Resistance to heat	B_{300} 30
Mechanical stability	$\Delta A_{throat} < 10\%$
Reaction to fire	
Insulated panel or glass	A1
Polycarbonate	B-s1;d0
Performance under environnemental conditions, as:	
Opening under load	SL NPD
Low ambient temperature	T(00)
Stability under wind load	WL 1500
Resistance to wind-induced vibration (where included)	$\omega_0: > 10Hz, \delta: > 0{,}1$
Resistance to heat	B_{300} 30
Durability, as:	
Response delay (response time)	≤ 60 s
Operational reliability	Re 1000
Performance parameters under fire conditions	≤ 60 s; $\Delta A_{throat} < 10\%$

Harmonised technical specification: EN 12101-2:2003

Calculation of the free aerodynamic surface :
$A_a = A_v \times C_v**$
$A_v = Lpa \times Hpa$

# DECLARATION OF PERFORMANCE OF SMOKE AND HEAT CONTROL SYSTEMS

**** Calculation of flow coefficient Without the influence of the"mullion-transom-construction":**

In the bottom / top hunged without mullion-transom-construction

- Lpa/Hpa ≤ 0,5
- 0,5 < Lpa/Hpa ≤ 1,0
- 1,0 < Lpa/Hpa ≤ 1,8
- Lpa/Hpa > 1,8

Inwards side hunged opening
Without mullion-transom-construction

- 0,32 ≤ Lpa/Hpa ≤ 0,54
- 0,54 < Lpa/Hpa ≤ 1,0
- 1,0 < Lpa/Hpa ≤ 2,0
- 2,0 < Lpa/Hpa

** Cv: Calculation of flow coefficient With the influence of the"mullion-transom-construction":

In the bottom / top hunged with mullion-transom-construction

- Lpa/Hpa ≤ 0,5
- 0,5 < Lpa/Hpa ≤ 1,0
- 1,0 < Lpa/Hpa ≤ 1,8
- Lpa/Hpa > 1,8

Inwards side hunged opening
With mullion-transom-construction

- 0,32 ≤ Lpa/Hpa ≤ 0,54
- 0,54 < Lpa/Hpa ≤ 1,0
- 1,0 < Lpa/Hpa ≤ 2,0
- 2,0 < Lpa/Hpa

10. *The performance of the product identified in points 1 et 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.*

Signed for and on behalf of the manufacturer by: **David Maillart – R&D Manager**

The 21/04/2023
In Collégien