

**DECLARATION OF PERFORMANCE OF SMOKE AND HEAT CONTROL SYSTEMS**1. *Unique identification code of the product-type:***CERTILAM TES  
CERTILAM TEI**2. *Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11 paragraph 4:*  
**Information given on the tracking label :****Order confirmation Number + Product Number + Date of production**3. *Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer :***3.1 Product description :**

Natural smoke and heat exhaust ventilator (NSHEV) for roof installation with aluminum blades which can be thermally or acoustically insulated.

**3.2 Installation and implementation conditions in accordance with the certified performances :**

- Roof installation from 0° to 60°
- Dimensional range: L and H are the throat dimensions of the product  
L = width in m and H = height in m  
0,421 ≤ H ≤ 3,546 and 0,5 ≤ L ≤ 2,400      With 0,21m<sup>2</sup> ≤ A<sub>v</sub>\* ≤ 7m<sup>2</sup>  
0,406 ≤ H ≤ 3,554 and 0,5 ≤ L ≤ 2,400      \* : A<sub>v</sub> = L x H

- With mandatory fixed windshields, to ensure Cv coefficient declared in page 2
- Without or with 280- or 350-mm high steel upstand, with or without insulation, to ensure Cv coefficient declared in page 2

**3.3 Mode of operation :**Electric opening and closing  
Voltage U<sub>a</sub> = U<sub>c</sub> = 24 Vcc – Wattage P<sub>a</sub> = P<sub>c</sub> absorbed in a steady state

- 12 W maxi with 1 motor from 3 to 5 blades.
- 19,2 W or 24 W maxi with 1 motor from 6 blades and more depending on the surface and the need to snowload.

**3.4 Possible options :**Open / Close position switches  
Thermal device release (according to the current standard).4. *Name, registered trade name or trade mark , in conformity with article 11, paragraph 5:***Company name :** SOUCHIER – BOULLET SAS  
Parc Segro – 42 rue de Lamirault  
CS 20762  
77090 COLLEGIEN  
France**Production unit :** SOUCHIER-BOULLET SAS  
11 rue du 47<sup>ème</sup> R.A.  
70400 HERICOURT  
France6. 7. *System or systems of assessment and verification of constancy of performance of the construction product in accordance to Annex V.*The notified body **TÜV Rheinland N° 0336** performed the determination of the product type on the basis of type testing, type calculation of the product, the initial inspection of the manufacturing plant and the factory production control and the continuous surveillance, assessment and evaluation of the factory production control under system 1 and issued the certificate of constancy of performance N°**CE Certificate N° 0336 – CPR – 6742-1-1**

N : DoP LAM TES-TEI\_ind D

## DECLARATION OF PERFORMANCE OF SMOKE AND HEAT CONTROL SYSTEMS

9. Declared performances :

Harmonised technical specification: EN 12101-2003	Essential characteristics	Performance
	<b>Nominal activation conditions / sensitivity, as :</b> Initiation device Opening mechanism Inputs and outputs	Présent Présent Présent
	<b>Response delay (response time), as :</b> Reliability Opening under (snow, wind) load Low ambient temperature Fire Performance	≤ 60 s
	<b>Operational reliability, as :</b> Reliability	Re 1000, Type B Re 1000 (+10 000), Type B
	<b>Effectiveness of smoke / hot gas extractions, as</b> Aerodynamic free area  With upstand Without upstand	  $A_0 = A_v^* \times C_v^{**}$ $A_0 = A_v^* \times C_v^{**}$
	<b>Performance parameters under fire conditions, as :</b> Resistance to heat Mechanical stability Reaction so fire :  Standard blades Insulated blades	  $B_{300} 30$ $\Delta A_{throat} < 10 \%$  A1 B-s1 ; d0
	<b>Performance under environmental conditions, as :</b> Opening under load (see tables) Low ambient temperature Stability under wind load Resistance to wind induced vibration (where included) Resistance to heat	SL *** T (-15) WL 1500 $\omega_0 > 10\text{Hz}$ , $\delta > 0,1$  $B_{300} 30$
<b>Durability, as :</b> Response delay (response time) Operational reliability Performance parameters under fire conditions	≤ 60 s Re 1000 Re 1000 (+10 000), ≤ 60 s, $\Delta A_{throat} < 10 \%$	

\*\*\***Determination of the snowload classification :**

CERTILAM TES :

Type of motor	Performance	Av
1 motor 0,8A or 1A	SL 500	0,2 to 3,3 m <sup>2</sup>
	SL 250	3,3 to 6 m <sup>2</sup>
1 motor (2 x 0,8A)	SL 500	3,3 to 6 m <sup>2</sup>
	SL 250	6 to 7 m <sup>2</sup> if L ≤ 2000 mm
	SL 0	6 to 7 m <sup>2</sup> if L > 2000 mm

CERTILAM TEI :

Type of motor	Performance	Av
1 motor 0,8A or 1A	SL 500	0,2 to 2,85 m <sup>2</sup>
	SL 250	2,85 to 5 m <sup>2</sup>
	SL 0	5 to 6 m <sup>2</sup>
1 motor (2 x 0,8A)	SL 500	2,85 to 5,7 m <sup>2</sup>
	SL 250	5,7 to 6 m <sup>2</sup> 6 to 7 m <sup>2</sup> TEI therm si L ≤ 2000 mm
	SL 0	6 to 7 m <sup>2</sup> TEI therm if L > 2000 mm and TEI phon all width

\*\***Definition of flow coefficient**

		With upstand 280 mm		With upstand 350 mm		Without upstand	
		500 ≤ L < 1000	1000 ≤ L ≤ 2400	500 ≤ L < 1000	1000 ≤ L ≤ 2400	500 ≤ L < 1000	1000 ≤ L ≤ 2400
With Av ≤ 6m <sup>2</sup> Windshields=265 mm	H < 1000	0,55	0,55			0,50	0,50
	H ≥ 1000	0,55	0,67			0,50	0,62
With Av > 6m <sup>2</sup> Windshields=310 mm	H ≤ 3554				0,64		0,62

10. The performance of the product identified in points 1 et 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by: **David Maillart – R&D Director**

The 16/12/2025  
In Collégien