



N: DoP LAM FMS-FMI indC

# **DECLARATION OF PERFORMANCE OF SMOKE AND HEAT CONTROL SYSTEMS**

Unique identification code of the product-type:

CERTILAM FMS
CERTILAM FMI

Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11 paragraph 4: Information given on the tracking label:

Order confirmation Number + Product Number + Date of production

3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:

#### 3.1 Product description:

Natural smoke and heat exhaust ventilator (NSHEV) for wall installation with aluminium blades which can be thermally or acoustically insulated.

#### 3.2 Installation and implementation conditions in accordance with the certified performances

- Wall installation from 0° to 30° except 0° for frame D
- Dimensional range: L and H are the throat dimensions of the product

**L** = width in m and **H** = height in m  $0.756 \le H \le 3,046 \text{ and } 0.5 \le L \le 2,400 \text{ with standard blades}$   $0.764 \le H \le 3,054 \text{ and } 0.5 \le L \le 2,400 \text{ with insulated blades}$ 

With  $1m^2 \le A_v^* \le 5m^2$ With  $1m^2 \le A_v^* \le 4,7m^2$ \*:  $A_v = L \times H$ 

## 3.3 Mode of operation :

Opening by intrinsic energy and rearming by steel cable traction

### 3.4 Possible options:

Open / Close position switches Thermal device release (according to the current standard). Small lateral windshields except for frame D.

4. Name, registered trade name or trade mark, in conformity with article 11, paragraph 5:

Company name: SOUCHIER – BOULLET SAS Parc Segro – 42 rue de Lamirault CS 20762 77090 COLLEGIEN France <u>Production unit</u>: SOUCHIER-BOULLET SAS 11 rue du 47<sup>ème</sup> R.A. 70400 HERICOURT France

5. 7. System or systems of assessment and verification of constancy of performance of the construction product in accordance to Annex V.

The notified body TÜV Rheinland N° 0336 performed the determination of the product type on the basis of type testing, type calculation of the product, the initial inspection of the manufacturing plant and the factory production control and the continuous surveillance, assessment and evaluation of the factory production control under system 1 and issued the certificate of constancy of performance N°

CE Certificate N°0336 - CPR - 6742-1-2











N: DoP LAM FMS-FMI\_indC

# **DECLARATION OF PERFORMANCE OF SMOKE AND HEAT CONTROL SYSTEMS**

# Declared performances:

	Essential characteristics	Performance
Nominal activa	tion conditions / sensitivity, as:	
	Initiation device	present
	Opening mechanism	present
	Inputs and outputs	present
Response delay	(response time), as:	
	Reliability	
	Opening under (snow, wind) load	≤ 60 s
	Low ambient temperature	2 00 3
	Fire Performance	
Operational rel	iability, as:	
	Reliability	Re 300 (+10 000), Type B
Effectiveness o	f smoke/hot gas extraction, as:	
	Aerodynamic free area	$A_a = A_v^* \times Cv^{**}$
Performance pa	arameters under fire conditions, as:	
	Resistance to heat	B <sub>300</sub> 30
	Mechanical stability	$\Delta A_{throat} < 10 \%$
	Reaction to fire	
	Standard blades	A1
	Insulated blades	B-s1;d0
Performance u	nder environnemental conditions, as:	
	Opening under load	SL NPD
	Low ambient temperature	T(-25)
	Stability under wind load	WL 1500
	Resistance to wind-induced vibration (where included)	$ω_0$ : > 10Hz, δ: >0,1
	Resistance to heat	B <sub>300</sub> 30
Durability, as:		
	Response delay (response time)	≤ 60 s
	Operational reliability	Re 300 (+10 000)
	Performance parameters under fire conditions	$\leq$ 60 s; $\Delta A_{throat} <$ 10 %

# \*\*Definition of flow coefficient

<u>Avec Av ≥ 1 m²</u>	500 ≤ L < 1000	1000 ≤ L ≤ 2400
H < 1000	Cv = 0,50	Cv = 0,50
H ≥ 1000	Cv = 0,50	Cv = 0,62

10. The performance of the product identified in points 1 et 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by: David Maillart – R&D Manager

The 18/04/2023 In Collégien







