

# AENOR

## AENOR Product Certificate Bituminous waterproofers



**032/002487**

AENOR certifies that the organization

### **SOPREMA S.A.**

registered office ZONA INDUSTRIAL DE ALPIARÇA, RUA A, LOTE 4B, 2090-242 ALPIARÇA (Portugal)

supplies Reinforced bitumen sheets for roof waterproofing

in compliance with UNE-EN 13707:2005+A2:2010 (EN 13707:2004+A2:2009)

Trade Mark Designation MORTERPLAS APP FP 4,8 KG  
Reinforcement LBM-48-FP  
POLYESTER FELT

See annex for more information.

Production site ZONA INDUSTRIAL DE ALPIARÇA, RUA A, LOTE 4B, 2090-242 ALPIARÇA (Portugal)

Certification scheme In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP 32.01.

First issued on 2020-04-16  
Validity date 2025-04-16

Rafael GARCÍA MEIRO  
Chief Executive Officer

# AENOR

## AENOR Product Certificate Bituminous waterproofers

032/002487

### Annex to Certificate

Trade Mark	MORTERPLAS APP FP 4,8 KG
Designation	LBM-48-FP
Reinforcement	POLYESTER FELT
External fire performance	Broof (t1)
Reaction to fire	E
Watertightness	YES
Shear resistance of joints	450±150 / 450±150
Maximum tensile force	700±200 / 450±150
Elongation	45±15 / 45±15
Resistance to root penetration	-
Resistance to impact	=1000
Resistance to static loading	=15
Dimensional stability	=0,4
Plegability at low temperature	-15
Flow resistance at elevated temperatures	=120
Durability: Plegability/Flow resistance	-
Adhesion of granules	-

First issued on 2020-04-16  
Validity date 2025-04-16

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.  
Génova, 6. 28004 Madrid. España  
Tel. 91 432 60 00.- www.aenor.com

Product certification body accredited by ENAC, number 1/C-PR271